



**MILBANK**  
ENERGY AT WORK

## U5168-XTL-100-KK



|                               |                                                                                                    |
|-------------------------------|----------------------------------------------------------------------------------------------------|
| Catalog Number                | U5168-XTL-100-KK                                                                                   |
| Marketing Product Description | 4 Terminal Ringless 2 Small Closing Plates 1-100 Ampere Main Breaker 10 Branch Circuit Horn Bypass |
| UPC                           | 784572475328                                                                                       |
| Length (IN)                   | 4.5                                                                                                |
| Width (IN)                    | 14.125                                                                                             |
| Height (IN)                   | 30                                                                                                 |
| Brand Name                    | Milbank                                                                                            |
| Type                          | Ringless Meter Socket                                                                              |
| Application                   | Meter Socket With Main And Load Center                                                             |
| Standard                      | UL Listed;Type 3R                                                                                  |
| Voltage Rating                | Up to 240 Volts Alternating Current                                                                |
| Amperage Rating               | 200 Continuous Ampere                                                                              |
| Phase                         | 1 Phase                                                                                            |
| Frequency Rating              | 60 Hertz                                                                                           |
| Size                          | 4.5L x 14.125W x 30H                                                                               |
| Number Of Cutouts             | 1                                                                                                  |
| Cutout Size                   | One 100 Ampere Main Breaker                                                                        |
| Cable Entry                   | Overhead or Underground                                                                            |
| Terminal                      | Lay in                                                                                             |

|                           |                                              |
|---------------------------|----------------------------------------------|
| Insulation                | Glass Polyester                              |
| Mounting                  | Surface Mount                                |
| Enclosure                 | G90 Galvanized Steel with Powder Coat Finish |
| Jaw Quantity              | 4 Terminal                                   |
| Bypass Type               | Horn Bypass                                  |
| Number of Meter Positions | 1 Position                                   |
| Equipment Ground          | Ground Bar                                   |
| Hub Opening               | Twin Small Closing Plates                    |
| Line Side Wire Range      | 6 AWG - 350 kcmil                            |
| Load Side Wire Range      | 6 AWG - 350 kcmil                            |
| Number Branch Circuits    | 8                                            |
| Number Of Receptacles     | 0                                            |

Please consult serving utility for their requirements prior to ordering or installing, as specifications and approvals vary by utility and may require local electrical inspector approval. All installations must be installed by a licensed electrician and must comply with all national and local codes, laws and regulations. Milbank reserves the right to make changes in specifications and features shown without notice or obligation.