

Product
PS-II Coupling Assembly
Project Information

Job Name:	Date Submitted:
Location:	Submitted By:
Engineer:	Approved By:
Contractor:	Manufacturer's Rep:

Installation

Must be installed in accordance with the TracPipe Design Guide and Installation Instructions and all applicable codes

Application Information

Connection of identical sizes of PS-II.

Technical Data
Materials

Nut, Adapter, Flange and Split Rings	Yellow Brass
Insert and 1" Split Ring	Stainless Steel

Pressure Ratings (used with tubing)

Specification Operating Pressure	25 PSIG
Max Test Pressure	40 PSIG

Temperature Ratings (used with tubing)

Operating Temperature Range	-20 to 200 Deg F
-----------------------------	------------------


Codes

ICC Codes (IFGC, IRC, IMC, IPC), NFPA 54, UPC, CAN/CSA B149.1, NFPA 58

Standards

ANSI LC1 / CSA 6.26, ANSI Z223.1

Listings

CSA, ICC PMG 1046 / 1052, IAPMO (UPC) File No. 4665

Dimensional Information

✓			Diameter across flats (Nom. in.)	Fitting length (Nom. in.)	TracPipe or CounterStrike Size	Weight (lbs)
Size	P/N					
<input type="checkbox"/> 3/8"	FGP-UGC-375		1"	6"	3/8"	0.65
<input type="checkbox"/> 1/2"	FGP-UGC-500		1-1/8"	6-1/4"	1/2"	0.70
<input type="checkbox"/> 3/4"	FGP-UGC-750		1-3/8"	7-1/8"	3/4"	1.05
<input type="checkbox"/> 1"	FGP-UGC-1000		1-5/8"	7-5/8"	1"	1.40
<input type="checkbox"/> 1-1/4"	FGP-UGC-1250		2-5/8"	8-3/8"	1-1/4"	2.50
<input type="checkbox"/> 1-1/2"	FGP-UGC-1500		3"	10-1/8"	1-1/2"	4.25
<input type="checkbox"/> 2"	FGP-UGC-2000		3-1/16"	10-5/8"	2"	6.90

Omega Flex, Inc. * 451 Creamery Way* Exton, PA 19341

Tel: 610-524-7272 * Toll Free: 800-671-8622 * Fax: 610-524-7282

www.omegaflex.com