

# Fusible Switch Lever Bypass Meter Stacks

Power Mod™

## Fusible Switch Lever Bypass Meter Stacks

This Commercial Lever Bypass Meter Stack (type WML) features a 400 Amp - Class T - Fusible Pull Out Assembly.

### Features include:

- QuickSystem features
- High-quality, time proven Talon HQ sockets
- Removable back knockout plate to facilitate wiring
- Available in single and three phases designs
- Single position with 400 Amp tenant main
- Ease of wiring

### Lever Bypass with Fusible Switch Quick Reference:

- 400A 1 position
- 1200A thru bus rating
- UL Standard #UL67
- UL file #E27100
- AIC rating 100KAIC
- Voltage
- Single phase
- Three phase in, single phase out
- Three Phase
- All swing latches and rivets are stainless steel
- Outdoor = NEMA 3R rated
- Indoor = NEMA 1 rated
- G90 Galvanized Steel
- ANSI 61 Paint



# Power Mod: Type WML Fusible Switch Lever Bypass

- 400A 1 position
- 1200A thru-bus rating
- 400A Class T fuse



Single-Phase in/out; Three-Phase in/ Single-Phase out; Three-Phase in/out

Outdoor Catalog Number	Indoor Catalog Number	Meter Positions Per Stack	Breaker Provisions	Maximum AIC	Dimensions (inches)®		
					Height	Width	Depth
Max. Tenant Breaker (Amps): 400							
WML11400RJFS	ML11400RJFS	1	Class T fuse	100K	38.31	16.34	11.22
WML12400RJFS	ML12400RJFS	1		100K	38.31	16.34	11.22
WML13400RJFS	ML13400RJFS	1		100K	38.31	16.34	11.22

① Dimensions shown are representative of the outside box dimensions and do not include allowances for mounting bumps, hubs, or hardware protrusions.



Siemens Industry, Inc.  
5400 Triangle Parkway  
Norcross, GA 30092  
  
1-800-241-4453  
info.us@siemens.com

Subject to change without prior notice  
Order No. RPFL-FSLBM-1215  
Printed in USA  
All rights reserved  
© 2015, Siemens Industry, Inc.

Subject to changes and errors. The information given in this document only contains general descriptions and/or performance features which may not always specifically reflect those described, or which may undergo modification in the course of further development of the products. The requested performance features are binding only when they are expressly agreed upon in the concluded contract.