


SUBMITTAL DRAWING

- ALL STEEL CONSTRUCTION
- MINIMUM SIZE = 4 X 8 MAXIMUM SIZE = 24 X 36
- FOR LARGER SIZES IN MULTIPLE SECTIONS CONSULT THE FACTORY
- Meets load test requirements of the International Mechanical Code Section 603.17.1 and H.U.D No. 58786
- EXTREMELY RIGID, SMOOTH SURFACE FACE
- FINISH: GOLDEN SAND (GS) ENAMEL



SIZE WIDTH	MAXIMUM DEPTH
4 THRU 18	0.80
20 THRU 24	1.55

JOB NAME: _____	SUBMITTED BY: _____	DATE: 04/13/2020	SD-2006
LOCATION: _____		265 Steel Heavy Duty Floor Grille	
ARCHITECT: _____			
ENGINEER: _____			
CONTRACTOR: _____			