



ENGINEERING BULLETIN

Subject: PRESTIGE PT Series Obsolete Components

Date: 10/12/20

Triangle Tube carried out a supply chain assessment in 2019 to ensure the long term availability of a number of components utilized in our boilers recognizing that replacement parts would be required throughout their expected lifetime.

In order to ensure continuity of supply, several changes to the components were required including the ignition components on the Prestige PT Series. Parts have been re-sourced and as a consequence when either an igniter or control module must be replaced on a Prestige PT Series boiler, these will be replaced with a kit containing the re-sourced components.

The replacement update kit includes a PU decal to affix over the PT serial number prefix on the rating label to readily identify units which have the replacement update kit installed.

Replacement Update Kit Part Numbers

| Model | Obsolete Control Module | Obsolete Igniter | Replacement Update Kit |
|------------------------|-------------------------|------------------|------------------------|
| Prestige PT60 & PT110 | PTRKIT205 | PTRKIT313 | PTRKIT301 |
| Prestige PT175 | PTRKIT205 | PTRKIT313 | PTRKIT302 |
| Prestige PT250 | PTRKIT206 | PTRKIT313 | PTRKIT305 |
| Prestige PT399 | PTRKIT206 | PTRKIT313 | PTRKIT303 |
| Prestige PT Excellence | PTRKIT205 | PTRKIT313 | PTRKIT304 |

In the event that individual parts are required after installing a replacement update kit, reference the table below for replacement part numbers.

Component Part Numbers of Replacement Update Kit

| Model | Control Module | Igniter | Spark Generator | Ignition Cable |
|------------------------------|----------------|-----------|-----------------|----------------|
| Prestige PT60 & PT110 & Exc. | PTRKIT306 | PTRKIT413 | PTRKIT308 | PTRKIT309 |
| Prestige PT175 | PTRKIT306 | PTRKIT513 | PTRKIT308 | PTRKIT309 |
| Prestige PT250 | PTRKIT307 | PTRKIT513 | PTRKIT308 | PTRKIT309 |
| Prestige PT399 | PTRKIT307 | PTRKIT613 | PTRKIT308 | PTRKIT309 |

Please contact technical support at (856) 228-8881 x575 with any questions regarding this issue.

Triangle Tube - 1240 Forest Parkway, Suite 100 - West Deptford, NJ 08066
Tel: 856 228 8881 - Fax: 856 228 3584 - e-mail: info@triangletube.com